CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-1319:101

CATEGORY: Control Unit (Household)

LISTEE: Home Automation, Inc., 5725 Powell Street, Suite A, New Orleans, LA 70123

Contact: David Hatty (504) 736-9810 *FAX (504) 736-9290

DESIGN: Models Omni, Omni Pro and Aegis combination household fire and burglary alarm

systems. Refer to listee's printed data sheet for additional detailed product description

and operational considerations. System components:

11A00-1, -2, -3, -4 Keypad

10A06, 1102 Zone Expander Transformer BE116440CAA 1503A0011 **EOL** Resistor

RATING: 120 VAC Primary, 12 VDC Standby

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

Listee's name, model number, electrical rating and UL label. MARKING:

APPROVAL: Listed as household fire alarm systems for use with separately listed electrically

compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer

to listee's Installation Instructions Manual for details.

NOTE: 1. Burglary and other non-fire functions were not examined.

2. Fire Alarm Verification feature (delay of fire alarm signal) is NOT approved for use in

California.

*Rev. 05-18-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 22, 2004 Date Issued: Listing Expires June 30, 2005

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager